



Ron N FAX (213) 481-4890
6th floor

TELECOPY

DATE 10/18/91

TO: Aaron Nissen, IPSC 801-864-4970

FROM: DLHaughey

NUMBER OF PAGES TO FOLLOW: 0

ANY PROBLEMS RECEIVING TELECOPY, PLEASE CALL: 303-988-8203

MESSAGE: Aaron: Fax received and forwarded to Barber for. A formal response will be initiated to the differences in approach:

1. Need for axial shunts, (on outer rings)
2. Desire to fix position of segments versus "Free Float"
3. Design temperature (which sets gaps).
4. Additional casing support. (Radial-throat sleeves)

We will provide this info, as well as schedule impact, as soon as possible. I will call early next week.

DLH

IP7_004021